

**§ 52.54 TESTING OF BACKFLOW PREVENTER.**

All testable backflow prevention assemblies shall be tested at the time of installation or relocation and after any repair. Subsequent testing of devices shall be conducted at a time interval specified by the Department of Public Works and in accordance with Michigan Department of Environmental Quality requirements. Only individuals that hold a valid Michigan plumbing license and hold an ASSE 5110 certification shall be approved to inspect and test a testable backflow device. Each tester shall also be approved by the Department of Public Works. Individual(s) performing assembly testing shall certify the results of his/her testing. (Ord. 16.1, passed 3-6-12; Am. Ord. passed 1-17-23)